



## Ohio Revised Code

### Section 3749.08 Pressure of pool and spa water features.

Effective: April 3, 2023

Legislation: House Bill 178 - 134th General Assembly

---

(A) The flow rate through a feature nozzle of a water feature, including a fountain or other interactive feature, at a public swimming pool, public spa, or special use pool shall be such as not to harm patrons and shall not exceed twenty feet per second unless justified by the design engineer and by the fountain system manufacturer.

(B) The owner of a public swimming pool, public spa, or special use pool shall ensure that the pool or spa meets the requirements of division (A) of this section.

---