



Ohio Administrative Code Rule 1301:7-7-21 Industrial ovens.

Effective: December 15, 2017

(A) Section 2101 General
(1) 2101.1 Scope. Dry cleaning plants and their operations shall comply with the requirements of this rule.
(2) 2101.2 Permit required. Permits shall be required as set forth in rule 1301:7-7-01 of the Administrative Code.
(B) Section 2102 Definitions
(1) 2102.1 Definitions. The following terms are defined in rule 1301:7-7-02 of the Administrative Code.
"Dry cleaning."
"Dry cleaning plant."
"Dry cleaning room."
"Dry cleaning system."
"Solvent or liquid classifications."
"Class I solvents."
"Class II solvents."
"Class IIIA solvents."





- 5. Type IV-systems using Class IV solvents in which dry cleaning is not conducted by the public.
- 6. Type V-systems using Class IV solvents in which dry cleaning is conducted by the public.

Spotting and pretreating operations conducted in accordance with paragraph (F)(2106) of this rule shall not change the type of the dry cleaning plant.


- (a) 2103.2.1 Multiple solvents. Dry cleaning plants using more than one class of solvent for dry cleaning shall be classified based on the numerically lowest solvent class.
- (3) 2103.3 Design. The occupancy classification, design and construction of dry cleaning plants shall comply with the applicable requirements of the building code as listed in rule 1301:7-7-80 of the Administrative Code.
- (D) Section 2104 General requirements
- (1) 2104.1 Prohibited use. Type I dry cleaning plants shall be prohibited. Limited quantities of Class I solvents stored and used in accordance with this paragraph shall not be prohibited in dry cleaning plants.
- (2) 2104.2 Building services. Building services and systems shall be designed, installed and maintained in accordance with this paragraph and rule 1301:7-7-06 of the Administrative Code.
- (a) 2104.2.1 Ventilation. Ventilation shall be provided in accordance with Section 502 of the mechanical code and DOL 29 CFR Part 1910.1000 as listed in rule 1301:7-7-80 of the Administrative Code, where applicable.
- (b) 2104.2.2 Heating. In Type II dry cleaning plants, heating shall be by indirect means using steam, hot water or hot oil only.
- (c) 2104.2.3 Electrical wiring and equipment. Electrical wiring and equipment in dry cleaning rooms or other locations subject to flammable vapors shall be installed in accordance with NFPA 70 as listed in rule 1301:7-7-80 of the Administrative Code.

- (d) 2104.2.4 Bonding and grounding. Storage tanks, treatment tanks, filters, pumps, piping, ducts, dry cleaning units, stills, tumblers, drying cabinets and other such equipment, where not inherently electrically conductive, shall be bonded together and grounded. Isolated equipment shall be grounded.
- (E) Section 2105 Operating requirements
- (1) 2105.1 General. The operation of dry cleaning systems shall comply with the requirements of paragraphs (E)(1)(a)(2105.1.1) to (E)(3)(2105.3) of this rule.
- (a) 2105.1.1 Written instructions. Written instructions covering the proper installation and safe operation and use of equipment and solvent shall be given to the buyer.
- (i) 2105.1.1.1 Type II, III-A, III-B and IV systems. In Type II, III-A, III-B and IV dry cleaning systems, machines shall be operated in accordance with the operating instructions furnished by the machinery manufacturer. Employees shall be instructed as to the hazards involved in their departments and in the work they perform.
- (ii) 2105.1.1.2 Type V systems. Operating instructions for customer use of Type V dry cleaning systems shall be conspicuously posted in a location near the dry cleaning unit. A telephone number shall be provided for emergency assistance.
- (b) 2105.1.2 Equipment identification. The manufacturer shall provide nameplates on dry cleaning machines indicating the class of solvent for which each machine is designed.
- (c) 2105.1.3 Open systems prohibited. Dry cleaning by immersion and agitation in open vessels shall be prohibited.
- (d) 2105.1.4 Prohibited use of solvent. The use of solvents with a flash point below that for which a machine is designed or listed shall be prohibited.
- (e) 2105.1.5 Equipment maintenance and housekeeping. Proper maintenance and operating practices



shall be observed in order to prevent the leakage of solvent or the accumulation of lint. The handling of waste material generated by dry cleaning operations and the maintenance of facilities shall comply with the provisions of this paragraph.

- (i) 2105.1.5.1 Floors. Class I and II liquids shall not be used for cleaning floors.
- (ii) 2105.1.5.2 Filters. Filter residue and other residues containing solvent shall be handled and disposed of in covered metal containers.
- (iii) 2105.1.5.3 Lint. Lint and refuse shall be removed from traps daily, deposited in approved waste cans, removed from the premises, and disposed of safely. At all other times, traps shall be held securely in place.
- (iv) 2105.1.5.4 Customer areas. In Type V dry cleaning systems, customer areas shall be kept clean.
- (2) 2105.2 Type II systems. Special operating requirements for Type II dry cleaning systems shall comply with the provisions of paragraphs (E)(2)(a)(2105.2.1) to (E)(2)(c)(2105.2.3) of this rule.
- (a) 2105.2.1 Inspection of materials. Materials to be dry cleaned shall be searched thoroughly and foreign materials, including matches and metallic substances, shall be removed.
- (b) 2105.2.2 Material transfer. In removing materials from the washer, provisions shall be made for minimizing the dripping of solvent on the floor. Where materials are transferred from a washer to a drain tub, a nonferrous metal drip apron shall be placed so that the apron rests on the drain tub and the cylinder of the washer.
- (c) 2105.2.3 Ventilation. A mechanical ventilation system which is designed to exhaust 1 cubic foot of air per minute for each square foot of floor area $[0.0058 \, \text{m}^3 \, / (\text{s} \cdot \text{m}^2)]$ shall be installed in dry cleaning rooms and in drying rooms. The ventilation system shall operate automatically when the dry cleaning equipment is in operation and shall have manual controls at an approved location.
- (3) 2105.3 Type IV and V systems. Type IV and V dry cleaning systems shall be provided with an automatically activated exhaust ventilation system to maintain a minimum of 100 feet per minute



(0.51 m/s) air velocity through the loading door when the door is opened. Such systems for dry cleaning equipment shall comply with the mechanical code as listed in rule 1301:7-7-80 of the Administrative Code.

Exception: Dry cleaning units are not required to be provided with exhaust ventilation where an exhaust hood is installed immediately outside of and above the loading door which operates at an airflow rate as follows:

$$Q = 100 \text{ x A}_{I,D}$$
 (Equation 21-1)

where:

Q = flow rate exhausted through the hood, cubic feet per minute (m³/s).


 A_{LD} = area of the loading door, square feet (m²).

- (F) Section 2106 Spotting and pretreating
- (1) 2106.1 General. Spotting and pretreating operations and equipment shall comply with the provisions of paragraphs (F)(2)(2106.2) to (F)(5)(2106.5) of this rule.
- (2) 2106.2 Class I solvents. The maximum quantity of Class I solvents permitted at any work station shall be 1 gallon (4 L). Spotting or prespotting shall be permitted to be conducted with Class I solvents where they are stored in and dispensed from approved safety cans or in sealed DOT-approved metal shipping containers of not more than 1-gallon (4 L) capacity.
- (a) 2106.2.1 Spotting and prespotting. Spotting and prespotting shall be permitted to be conducted with Class I solvents where dispensed from plastic containers of not more than 1 pint (0.5 L) capacity.
- (3) 2106.3 Class II and III solvents. Scouring, brushing, and spotting and pretreating shall be permitted to be conducted with Class II or III solvents. The maximum quantity of Class II or III solvents permitted at any work station shall be 1 gallon (4 L). In other than Group H-2 occupancy, the aggregate quantities of solvents shall not exceed the maximum allowable quantity per control



area for use-open system.

- (a) 2106.3.1 Spotting tables. Scouring, brushing or spotting tables on which articles are soaked in solvent shall have a liquid-tight top with a curb on all sides not less than 1 inch (25 mm) high. The top of the table shall be pitched to ensure thorough draining to a 1-inch (38 mm) drain connected to an approved container.
- (b) 2106.3.2 Special handling. Where approved, articles that cannot be washed in the usual washing machines are allowed to be cleaned in scrubbing tubs. Scrubbing tubs shall comply with the following:
- (i) Only Class II or III liquids shall be used.
- (ii) The total amount of solvent used in such open—containers shall not exceed 3 gallons (11 L).
- (iii) Scrubbing tubs shall be secured to the floor.
- (iv) Scrubbing tubs shall be provided with permanent 1-inch (38 mm) drains. Such drain shall be provided with a trap and shall be connected to an approved container.
- (c) 2106.3.3 Ventilation. Scrubbing tubs, scouring, brushing or spotting operations shall be located such that solvent vapors are captured and exhausted by the ventilating system.
- (d) 2106.3.4 Bonding and grounding. Metal scouring, brushing and spotting tables and scrubbing tubs shall be permanently and effectively bonded and grounded.
- (4) 2106.4 Type IV systems. Flammable and combustible liquids used for spotting operations shall be stored in approved safety cans or in sealed DOTn-approved shipping containers of not more than 1 gallon (4 L) in capacity. Aggregate amounts shall not exceed 10 gallons (38 L).
- (5) 2106.5 Type V systems. Spotting operations using flammable or combustible liquids are prohibited in Type V dry cleaning systems.




(G) Section 2107 Dry cleaning systems

- (1) 2107.1 General equipment requirements. Dry cleaning systems, including dry cleaning units, washing machines, stills, drying cabinets, tumblers and their appurtenances, including pumps, piping, valves, filters and solvent coolers, shall be installed and maintained in accordance with NFPA 32 as listed in rule 1301:7-7-80 of the Administrative Code. The construction of buildings in which such systems are located shall comply with the requirements of this paragraph and the building code as listed in rule 1301:7-7-80 of the Administrative Code.
- (2) 2107.2 Type II systems. Type II dry cleaning and solvent tank storage rooms shall not be located below grade or above the lowest floor level of the building and shall comply with paragraphs (G)(2)(a)(2107.2.1) to (G)(2)(c)(2107.2.3) of this rule.

Exception: Solvent storage tanks installed underground, in vaults or in special enclosures in accordance with rule 1301:7-7-57 of the Administrative Code.

- (a) 2107.2.1 Fire-fighting access. Type II dry cleaning plants shall be located so that access is provided and maintained from one side for fire-fighting and fire control purposes in accordance with paragraph (C)(503) of rule 1301:7-7-05 of the Administrative Code.
- (b) 2107.2.2 Number of means of egress. Type II dry cleaning rooms shall have not less than two means of egress doors located at opposite ends of the room, not less than one of which shall lead directly to the outside.
- (c) 2107.2.3 Spill control and secondary containment. Curbs, drains, or other provisions for spill control and secondary containment shall be provided in accordance with paragraph (D)(2)(5004.2) of rule 1301:7-7-50 of the Administrative Code to collect solvent leakage and fire protection water and direct it to a safe location.
- (3) 2107.3 Solvent storage tanks. Solvent storage tanks for Class II, IIIA and IIIB liquids shall conform to the requirements of rule 1301:7-7-57 of the Administrative Code and be located underground or outside, above ground.




Exception: As provided in NFPA 32 as listed in rule 1301:7-7-80 of the Administrative Code for inside storage or treatment tanks.

(H) Section 2108 Fire protection

- (1) 2108.1 General. Where required by this paragraph, fire protection systems, devices and equipment shall be installed, inspected, tested and maintained in accordance with rule 1301:7-7-09 of the Administrative Code.
- (2) 2108.2 Automatic sprinkler system. An automatic sprinkler system shall be installed in accordance with paragraph (C)(3)(a)(i)(903.3.1.1) of rule 1301:7-7-09 of the Administrative Code throughout dry cleaning plants containing Type II, Type III-A or Type III-B dry cleaning systems.

Exceptions:

- 1. An automatic sprinkler system shall not be required in Type III-A dry cleaning plants where the aggregate quantity of Class III-A solvent in dry cleaning machines and storage does not exceed 330 gallons (1250 L) and dry cleaning machines are equipped with a feature that will accomplish any one of the following:
- 1.1 Prevent oxygen concentrations from reaching 8 per cent or more by volume.
- 1.2 Keep the temperature of the solvent not less than 30° F (16.7° C) below the flash point.
- 1.3 Maintain the solvent vapor concentration at a level lower than 25 per cent of the lower explosive limit (LEL).
- 1.4 Utilize equipment approved for use in Class I, Division 2 hazardous locations in accordance with NFPA 70 as listed in rule 1301:7-7-80 of the Administrative Code.
- 1.5 Utilize an integrated dry-chemical, clean agent or water-mist automatic fire-extinguishing system designed in accordance with rule 1301:7-7-09 of the Administrative Code.



- 2. An automatic sprinkler system shall not be required in Type III-B dry cleaning plants where the aggregate quantity of Class III-B solvent in dry cleaning machines and storage does not exceed 3,300 gallons (12 490 L).
- (3) 2108.3 Automatic fire-extinguishing systems. Type II dry cleaning units, washer-extractors, and drying tumblers in Type II dry cleaning plants shall be provided with an approved automatic fire-extinguishing system installed and maintained in accordance with rule 1301:7-7-09 of the Administrative Code.

Exception: Where approved, a manual steam jet not less than inch (19 mm) with a continuously available steam supply at a pressure not less than 15 pounds per square inch gauge (psig) (103 kPa) is allowed to be substituted for the automatic fire-extinguishing system.

(4) 2108.4 Portable fire extinguishers. Portable fire extinguishers shall be selected, installed and maintained in accordance with this paragraph and paragraph (F)(906) of rule 1301:7-7-09 of the Administrative Code. A minimum of two 2-A:10-B:C portable fire extinguishers shall be provided near the doors inside dry cleaning rooms containing Type II, Type III-A and Type III-B dry cleaning systems.