

Ohio Administrative Code

Rule 3745-18-28 Erie county emission limits.

Effective: February 3, 2022

(A) No owner or operator of any coal-fired steam generating unit in Erie county, unless otherwise
specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed
a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
(B) [Reserved.]
(C) [Reserved.]
(D) [Reserved.]
(E) [Decembed]
(E) [Reserved.]
(F) The "Carmeuse Lime Inc Huron Plant" (OEPA premise number 0322010062) or any
subsequent owner or operator of the Carmeuse Lime Inc - Huron Plant, 100 Meeker street, Huron,
Ohio" shall not cause or permit the emission of sulfur dioxide from lime kiln numbers 1, 2, 3
(OEPA source numbers P901 to P903) to exceed a maximum of 4.0 pounds of sulfur dioxide per tor
of product.