



Ohio Administrative Code

Rule 4101:4-4-01 Design of boilers and pressure vessels.

Effective: July 1, 2007

(A) All new boilers and pressure vessels proposed for use in the state of Ohio, except those exempt by division (A) of section 4104.04 of the Revised Code, shall be designed in accordance with the applicable approved referenced standard(s) adopted in "Table 4101:4-3-01" of rule 4101:4-3-01 of the Administrative Code and other requirements as prescribed in rules 4101:4-4-01 to 4101:4-4-04 of the Administrative Code.

(B) A boiler having the standard stamping of another state that has adopted rules of construction equivalent to those of Ohio may be accepted by the superintendent provided that the person desiring to install the boiler shall make application to the superintendent for the installation and shall include the manufacturers' data report covering the construction of the boiler.

(C) All electric boilers shall be wired and the shell grounded, in accordance with "NFPA 70, the National Electric Code" referenced in rule 4101:1-35-01 of the Administrative Code.
