



Ohio Administrative Code Rule 4101:4-4-05 Clearances.

Effective: July 1, 2007

When boilers are replaced or new boilers installed in either existing or new buildings, a minimum clear space of three feet shall be provided on the control and service sides of the boiler. All other sides shall comply with the boiler manufacturer's installation instructions for clearances to combustible materials. All boilers shall be so located that adequate space will be provided for the proper operation of the boiler and its appurtenances, for the inspection of all surfaces, tubes, water walls, economizer piping, valves, and other equipment, and for their necessary maintenance and repair.
