

**4101:8-17-01 Combustion air.**

*[Comment: When a reference is made within this rule to a federal statutory provision, an industry consensus standard, or any other technical publication, the specific date and title of the publication as well as the name and address of the promulgating agency are listed in rule 4101:8-44-01 of the Administrative Code. The application of the referenced standards shall be limited and as prescribed in section 102.5 of rule 4101:8-1-01 of the Administrative Code.]*

**SECTION 1701**  
**GENERAL**

**1701.1 Scope.** Solid fuel-burning appliances shall be provided with combustion air in accordance with the appliance manufacturer's installation instructions. Oil-fired appliances shall be provided with combustion air in accordance with NFPA 31. The methods of providing combustion air in this chapter do not apply to fireplaces, fireplace stoves and direct-vent appliances. The requirements for combustion and dilution air for gas-fired appliances shall be in accordance with Chapter 24.

**1701.2 Opening location.** In flood hazard areas as established in Table 301.2(1), combustion air openings shall be located at or above the elevation required in Section 322.2.1 or 322.3.2.

Replaces: 4101:8-17-01  
Effective: 7/1/2019  
Five Year Review (FYR) Dates: 07/01/2024

CERTIFIED ELECTRONICALLY

---

Certification

12/14/2018

---

Date

Promulgated Under: 119.03  
Statutory Authority: 3781.10(A)(1)  
Rule Amplifies: 3781.06, 3781.01, 4740.14, 3791.04, 3781.11, 3781.10  
Prior Effective Dates: 01/01/2013