



## Ohio Administrative Code Rule 3701:1-52-23 Inspection and maintenance.

Effective: October 8, 2007

---

(A) The licensee shall perform inspection and maintenance checks that include, as a minimum, each of the following at the frequency specified in the license or license application:

(1) Operability of each aspect of the access control system required by rule 3701:1-52-08 of the Administrative Code.

(2) Functioning of the source position indicator required by paragraph (B) of rule 3701:1-52-12 of the Administrative Code.

(3) Operability of the radiation monitor for radioactive contamination in pool water required by paragraph (B) of rule 3701:1-52-22 of the Administrative Code using a radiation check source, if applicable.

(4) Operability of the over-pool radiation monitor at underwater irradiators as required by paragraph (B) of rule 3701:1-52-11 of the Administrative Code.

(5) Operability of the product exit monitor required by paragraph (A) of rule 3701:1-52-11 of the Administrative Code.

(6) Operability of the emergency source return control required by paragraph (C) of rule 3701:1-52-12 of the Administrative Code.

(7) A visual inspection of the leak-tightness of systems through which pool water circulates.

(8) Without turning extinguishers on, operability of the heat and smoke detectors and extinguisher system required by rule 3701:1-52-10 of the Administrative Code.

(9) Operability of the means of pool water replenishment required by paragraph (C) of rule 3701:1-



52-13 of the Administrative Code.

(10) Operability of the indicators of high and low pool water levels required by paragraph (D) of rule 3701:1-52-13 of the Administrative Code.

(11) Operability of the intrusion alarm required by paragraph (I) of rule 3701:1-52-08 of the Administrative Code, if applicable.

(12) Functioning and wear of the system, mechanisms, and cables used to raise and lower sources.

(13) Condition of the barrier to prevent products from hitting the sources or source mechanism as required by rule 3701:1-52-14 of the Administrative Code.

(14) Amount of water added to the pool to determine if the pool is leaking.

(15) Electrical wiring on required safety systems for radiation damage.

(16) Pool water conductivity measurements and analysis as required by paragraph (B) of rule 3701:1-52-24 of the Administrative Code.

(B) Malfunctions and defects found during inspection and maintenance checks must be repaired without undue delay.