



Ohio Administrative Code

Rule 3745-18-02 General countywide emission limits.

Effective: February 3, 2022

No owner or operator of any coal-fired steam generating unit in the following counties shall cause or permit the emission of sulfur dioxide from any source to exceed the following limits:

(A)

(1) For sources in Adams county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Ashland county, a maximum of 7.2 pounds of sulfur dioxide per MM Btu actual heat input.

(3) For sources of Auglaize county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(B)

(1) For sources in Belmont county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Brown county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(C)

(1) For sources in Carroll county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Champaign county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu



actual heat input.

(3) For sources in Clark county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(4) For sources in Clermont county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(5) For sources in Clinton county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(6) For sources in Columbiana county, a maximum of 4.4 pounds of sulfur dioxide per MM Btu actual heat input.

(7) For sources in Coshocton county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(D)

(1) For sources in Darke county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Delaware county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(E) [Reserved.]

(F)

(1) For sources in Fairfield county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Fayette county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual



heat input.

(3) For sources in Fulton county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(G)

(1) For sources in Geauga county, a maximum of 7.2 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Guernsey county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(H)

(1) For sources in Hancock county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Hardin county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(3) For sources in Harrison county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(4) For sources in Henry county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(5) For sources in Highland county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(6) For sources in Hocking county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.



(7) For sources in Holmes county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(8) For sources in Huron county, a maximum of 8.0 pounds of sulfur dioxide per MM Btu actual heat input.

(I) [Reserved.]

(J) For sources in Jackson county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(K) For sources in Knox county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(L)

(1) For sources in Lawrence county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Licking county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(3) For sources in Logan county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(M)

(1) For sources in Madison county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Marion county, a maximum of 6.1 pounds of sulfur dioxide per MM Btu actual heat input.



(3) For sources in Medina county, a maximum of 8.0 pounds of sulfur dioxide per MM Btu actual heat input.

(4) For sources in Meigs county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(5) For sources in Mercer county, a maximum of 8.0 pounds of sulfur dioxide per MM Btu actual heat input.

(6) For sources in Monroe county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(7) For sources in Morgan county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(8) For sources in Morrow county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(N) For sources in Noble county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(O) [Reserved.]

(P)

(1) For sources in Perry county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Pickaway county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(3) For sources in Pike county, a maximum of 7.0 pounds of sulfur dioxide per MM Btu actual heat input.



(4) For sources in Portage county, a maximum of 7.2 pounds of sulfur dioxide per MM Btu actual heat input.

(5) For sources in Preble county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(6) For sources in Putnam county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(Q) [Reserved.]

(R) For sources in Richland county, a maximum of 7.1 pounds of sulfur dioxide per MM Btu actual heat input.

(S)

(1) For sources in Scioto county, a maximum of 6.9 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Shelby county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(T) [Reserved.]

(U) For sources in Union county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(V)

(1) For sources in Van Wert county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.



(2) For sources in Vinton county, a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(W)

(1) For sources in Warren county, a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

(2) For sources in Wood county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

(3) For sources in Wyandot county, a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.