



Ohio Administrative Code

Rule 3745-18-10 Ashtabula county emissions limits.

Effective: February 3, 2022

(A) No owner or operator of any coal-fired steam generating unit in Ashtabula county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 7.2 pounds of sulfur dioxide per MM Btu actual heat input.

(B) [Reserved.]

(C) [Reserved.]

(D) [Reserved.]

(E) [Reserved.]

(F) [Reserved.]

(G) [Reserved.]

(H) The "EMC Ashtabula, LP" (OEPA premise number 0204010003) or any subsequent owner or operator of the "EMC Ashtabula, LP, Ashtabula, Ohio" shall not cause or permit the emission of sulfur dioxide from the vertical lime kiln numbers 3 and 2 (OEPA source numbers P009, P010) to exceed a maximum of 3.1 pounds of sulfur dioxide per ton of process weight input.
