



## Ohio Administrative Code Rule 3745-18-11 Athens county emission limits.

Effective: February 3, 2022

---

(A) No owner or operator of any coal-fired steam generating unit in Athens county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(B) [Reserved.]

(C) The "Ohio University-Lausche Heating Plant" (OEPA premise number 0605010016) or any subsequent owner or operator of the "Ohio University-Lausche Heating Plant, Factory Street, Athens, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler number 136642 (OEPA source number B042) to exceed a maximum of 4.7 pounds of sulfur dioxide per MM Btu actual heat input from the boiler.

---