



Ohio Administrative Code Rule 3745-18-33 Gallia county emission limits.

Effective: February 3, 2022

(A) No owner or operator of any coal-fired steam generating unit in Gallia county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(B) The "Ohio Valley Electric Corporation, Kyger Creek Station" (OEPA premise number 0627000003) or any subsequent owner or operator of the "Ohio Valley Electric Corporation, Kyger Creek Station, 5758 State Route 7 North, Cheshire, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 to 5 (OEPA source numbers B001 to B005) to exceed a maximum of 8.2 pounds of sulfur dioxide per MM Btu actual heat input from each stack.

(C) [Reserved.]

(D) The "General James M. Gavin Power Plant" (OEPA premise numbers 0627010056) or any subsequent owner or operator of the "General James M. Gavin Power Plant, 7397 N St Rt #7, Cheshire, Ohio" shall not cause or permit the emission of sulfur dioxide from unit one main boiler and unit two main boiler (OEPA source numbers B003 and B004) to exceed a maximum of 7.41 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
