



## Ohio Administrative Code Rule 3745-18-61 Miami county emission limits.

Effective: February 3, 2022

---

(A) No owner or operator of any coal-fired steam generating unit in Miami county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.2 pounds of sulfur dioxide per MM Btu actual heat input.

(B) The "Piqua Municipal Power System" (OEPA premise number 0855100041) or any subsequent owner or operator of the "Piqua Municipal Power System, 919 South Main street, Piqua, Ohio" shall not cause or permit the emission of sulfur dioxide from CT number 8 oil-fired boiler (OEPA source number B007) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input.

---