



Ohio Administrative Code Rule 3745-18-63 Montgomery county emission limits.

Effective: February 3, 2022

(A) No owner or operator of any coal-fired steam generating unit in Montgomery county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 1.5 pounds of sulfur dioxide per MM Btu actual heat input.

(B) [Reserved.]

(C) [Reserved.]

(D) [Reserved.]

(E) [Reserved.]

(F) [Reserved.]

(G) [Reserved.]

(H) [Reserved.]

(I) The "Tait Generating Station" (OEPA premise number 0857043333) or any subsequent owner or operator of the "Tait Generating Station, 2101 Arbor Blvd., Moraine, Ohio" shall not cause or permit the emission of sulfur dioxide from oil-fired IC units T-1 to T-4 (OEPA source numbers B507 to B510) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each unit.

(J) [Reserved.]

(K) [Reserved.]



(L) [Reserved.]

(M) The "O.H. Hutchings CT" (OEPA premise number 0857780013) or any subsequent owner or operator of the "O.H. Hutchings CT, 9200 Chautauqua Road, Miamisburg, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine number 7 (OEPA source number B007) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input.

(N) The "Yankee Street" (OEPA premise number 0857810015) or any subsequent owner or operator of the "Yankee Street, 9975 Yankee Street, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine numbers y-1 to y-7 (OEPA source numbers B001 to B007) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.

(O) [Reserved.]

(P) [Reserved.]

(Q) [Reserved.]

(R) [Reserved.]

(S) [Reserved.]

(T) The "Tate & Lyle, Dayton" (OEPA premise number 0857041333) or any subsequent owner or operator of the "Tate & Lyle, Dayton, 5600 Brentlinger Drive, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from unit numbers 1 and 2 (OEPA source numbers B001 and B002) to exceed a maximum of 0.8 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.