



Ohio Administrative Code

Rule 3745-18-85 Tuscarawas county emission limits.

Effective: February 3, 2022

(A) No owner or operator of any coal-fired steam generating unit in Tuscarawas county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(B) [Reserved.]

(C) [Reserved.]

(D) [Reserved.]

(E) The "Dover Municipal Light Plant" (OEPA premise number 0679010146) or any subsequent owner or operator of the "Dover Municipal Light Plant, 303 East Broadway, Dover, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler number 4 (OEPA source number B004) to exceed a maximum of 4.6 pounds of sulfur dioxide per MM Btu actual heat input.
