



Ohio Administrative Code

Rule 3745-267-190 Applicability - tank systems - standardized permitting.

Effective: [March 7, 2025](#)

Rules 3745-267-190 to 3745-267-204 of the Administrative Code apply to owners or operators of facilities that treat or store hazardous waste in above-ground or on-ground tanks under a standardized permit pursuant to rules 3745-50-250 to 3745-50-320 of the Administrative Code, except as provided in paragraph (B) of rule 3745-267-01 of the Administrative Code.

(A) Owners or operators do not have to meet the secondary containment requirements in rule 3745-267-195 of the Administrative Code if the tank system does not contain free liquids and is situated inside a building with an impermeable floor. Owners or operators shall demonstrate the absence or presence of free liquids in the stored and treated waste, using method 9095B (paint filter liquids test) as described in "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods," U.S. EPA publication SW-846.

(B) Owners or operators do not have to meet the secondary containment requirements of paragraph (A) of rule 3745-267-195 of the Administrative Code if the tank system, including "sumps" as defined in rule 3745-50-10 of the Administrative Code, is part of a secondary containment system to collect or contain releases of hazardous wastes.

[Comment: For dates of non-regulatory government publications, publications of recognized organizations and associations, federal rules, and federal statutory provisions referenced in this rule, see rule 3745-50-11 of the Administrative Code titled "Incorporated by reference."]
