



Ohio Administrative Code

Rule 3745-267-192 Handling and inspection procedures during installation of new tank systems - tank systems - standardized permitting.

Effective: March 7, 2025

(A) The owner or operator shall ensure that the facility follows proper handling procedures to prevent damage to a new tank system during installation. Before placing a new tank system or component in use, an independent, qualified installation inspector or an independent, qualified, registered professional engineer, either of whom is trained and experienced in the proper installation of tank systems or components, shall inspect the system for the presence of any of the following items:

- (1) Weld breaks.
- (2) Punctures.
- (3) Scrapes of protective coatings.
- (4) Cracks.
- (5) Corrosion.
- (6) Other structural damage or inadequate construction or installation.

(B) The owner or operator shall remedy all discrepancies before the tank system is placed in use.
