



Ohio Administrative Code

Rule 3745-267-194 Installation - tank systems - standardized permitting.

Effective: [March 7, 2025](#)

(A) The owner or operator shall support and protect ancillary equipment against physical damage and excessive stress due to settlement, vibration, expansion, or contraction.

(B) The owner or operator shall provide the type and degree of corrosion protection recommended by an independent corrosion expert, based on the information provided under paragraph (C) of rule 3745-267-191 of the Administrative Code, to ensure the integrity of the tank system during use of the tank system. An independent corrosion expert shall supervise the installation of a corrosion protection system that is field fabricated to ensure proper installation.

(C) The owner or operator shall obtain, and keep at the facility, written statements by those persons required to certify the design of the tank system and to supervise the installation of the tank system as required in rules 3745-267-192 and 3745-267-193 of the Administrative Code, and paragraphs (A) and (B) of this rule. The written statement shall attest that the tank system was properly designed and installed and that the owner or operator made repairs under rules 3745-267-192 and 3745-267-193 of the Administrative Code. These written statements shall also include the certification statement as required in paragraph (D) of rule 3745-50-42 of the Administrative Code.
