



Ohio Administrative Code

Rule 3745-267-197 Ancillary equipment - tank systems - standardized permitting.

Effective: [March 7, 2025](#)

The owner or operator shall provide ancillary equipment with secondary containment (for example, trench, jacketing, double-walled piping) that meets the requirements of paragraphs (A) and (B) of rule 3745-267-195 of the Administrative Code, except for:

- (A) Above ground piping (exclusive of flanges, joints, valves, and other connections) that are visually inspected for leaks on a daily basis;
 - (B) Welded flanges, welded joints, and welded connections, that are visually inspected for leaks on a daily basis;
 - (C) Sealless or magnetic coupling pumps and sealless valves, that are visually inspected for leaks on a daily basis; and
 - (D) Pressurized above ground piping systems with automatic shut-off devices (for example, excess flow check valves, flow metering shutdown devices, loss of pressure actuated shut-off devices) that are visually inspected for leaks on a daily basis.
-