



Ohio Administrative Code

Rule 3745-267-202 Special requirements for ignitable wastes or reactive wastes - tank systems - standardized permitting.

Effective: March 7, 2025

(A) Owners or operators may not place ignitable waste or reactive waste in tank systems, unless:

(1) Owners or operators treat, render, or mix the waste before or immediately after placement in the tank system so that:

(a) The owners or operators comply with paragraph (B) of rule 3745-267-17 of the Administrative Code; and

(b) The resulting waste, mixture, or dissolved material no longer meets the definition of ignitable waste or reactive waste under rule 3745-51-21 or 3745-51-23 of the Administrative Code; or

(2) Owners or operators store or treat the waste in such a way that the waste is protected from any material or conditions that may cause the waste to ignite or react; or

(3) Owners or operators use the tank system solely for emergencies.

(B) If owners or operators store or treat ignitable waste or reactive waste in a tank, the owners or operators shall comply with the requirements for the maintenance of protective distances between the waste management area and any public ways, streets, alleys, or an adjoining property line that can be built upon as required in the national fire protection association's (NFPA) "Flammable and Combustible Liquids Code."

[Comment: For dates of non-regulatory government publications, publications of recognized organizations and associations, federal rules, and federal statutory provisions referenced in this rule, see rule 3745-50-11 of the Administrative Code titled "Incorporated by reference."]
