



Ohio Administrative Code

Rule 3745-51-198 Special requirements for ignitable or reactive materials - tank systems.

Effective: June 12, 2023

(A) Ignitable or reactive material shall not be placed in tank systems, unless the material is stored or treated in such a way that the ignitable or reactive material is protected from any material or conditions that may cause the material to ignite or react.

(B) The remanufacturer or other person who stores or treats hazardous secondary material which is ignitable or reactive shall store or treat the hazardous secondary material in a tank that is in compliance with the requirements for the maintenance of protective distances between the material management area and any public ways, streets, alleys, or an adjoining property line that can be built upon as required in the tables in the national fire protection association's (NFPA) "Flammable and Combustible Liquids Code."

[Comment: For dates of non-regulatory government publications, publications of recognized organizations and associations, federal rules, and federal statutory provisions referenced in this rule, see rule 3745-50-11 of the Administrative Code titled "Incorporated by reference."]
