



## Ohio Administrative Code

### Rule 3745-55-76 Special requirements for ignitable or reactive waste.

Effective: January 7, 1983

---

Containers holding ignitable or reactive waste must be located at least fifteen meters (fifty feet) from the facility's property line.

[Comment: See paragraph (A) of rule 3745-54-17 of the Administrative Code for additional requirements.]

---