



Ohio Administrative Code Rule 3745-555-215 Conveyance pipes.

Effective: April 1, 2017

This rule is applicable as specified in rule 3745-555-200 of the Administrative Code.

Conveyance pipes shall be designed to meet the following criteria:

- (A) Have a diameter and schedule capable of conveying the anticipated amount of fluid under anticipated operating pressures.
 - (B) Be protected from damage caused by freezing temperatures, crushing, and deflection.
 - (C) Be capable of being inspected for leaks.
-