



Ohio Administrative Code

Rule 3745-82-02 Secondary maximum contaminant levels.

Effective: September 13, 1993

The secondary maximum contaminant levels for public water systems are as follows

Contaminant	Level
Aluminum *	0.05 to 0.2 mg/L
Chloride	250 mg/L
Color	15 color units
Corrosivity	non-corrosive
Fluoride	2.0 mg/L
Foaming Agents	0.5 mg/L
Iron	0.3 mg/L
Manganese	0.05 mg/L
Odor	3 threshold odor number
pH	7.0 - 10.5
Silver	0.1 mg/L
Sulfate	250 mg/L
Total dissolved solids (TDS)	500 mg/L
Zinc	5 mg/L

* The secondary maximum contaminant level for aluminum is a range, with the precise level applicable to each public water system to be determined by the director.
