



Ohio Administrative Code Rule 901:5-3-05 Location of containers.

Effective: November 18, 1978

(A) Consideration shall be given to the physiological effects of ammonia as well as to adjacent fire hazards in selecting the location for a storage container. Containers shall be located outside of any building or in a building or section thereof especially approved for this purpose;

(B) Containers shall be located at least fifty feet from a dug well or other sources of potable water supply;

(C) The location of permanent storage containers shall be outside densely populated areas;

(D) Container locations shall comply with the following table:

	Minimum distances (feet) from Container to:	Nominal Capacity of Container (Gallons)	Line of Adjoining Property which may be built upon, Highways & Mainline of Railroad
Place of Public Assembly	Institution Occupancy	Over 500 to 2,000	25
150	200	Over 2,000 to 30,000	50
300	500	Over 30,000 to 100,000	50
450	750	Over 100,000	50

(E) Storage areas shall be kept free at all times of readily ignitable materials such as, but not limited to, waste, weeds and long dry grass.
