



## Ohio Administrative Code Rule 3745-66-90 Applicability- tanks.

Effective: October 5, 2020

---

Rules 3745-66-90 to 3745-66-100 of the Administrative Code apply to owners and operators of facilities that use tanksystems to store or treat hazardous waste except as otherwise provided in paragraphs (A), (B), and (C) of this rule or in rule 3745-65-01 of the Administrative Code.

(A) Tank systems that are used to store or treat hazardous waste which contains no free liquids and that are situated inside a building with an impermeable floor are exempted from rule 3745-66-93 of the Administrative Code. To demonstrate the absence or presence of free liquids in the stored or treated waste, the following test shall be used method 9095B ("Paint Filter Liquids Test") as described in "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods," U.S. EPA publication SW-846.

(B) Tank systems, including "sumps," as defined in rule 3745-50-10 of the Administrative Code, that serve as part of a secondary containment system to collect or contain releases of hazardous wastes, are exempted from paragraph (A) of rule 3745-66-93 of the Administrative Code.

(C) Tanks, sumps, and other collection devices used in conjunction with "drip pads," as defined in rule 3745-50-10 of the Administrative Code, and regulated under rules 3745-69-40 to 3745-69-45 of the Administrative Code, shall comply with rules 3745-66-90 to 3745-66-100 of the Administrative Code.

[Comment: For dates of non-regulatory government publications, publications of recognized organizations and associations, federal rules, and federal statutory provisions referenced in this rule, see rule 3745-50-11 of the Administrative Code titled "Incorporated by reference."]

---