



Ohio Administrative Code

Rule 3745-81-44 Ground water rule - treatment technique violations for ground water systems.

Effective: [December 12, 2022](#)

(A) A ground water system with a significant deficiency is in violation of the treatment technique requirement if the system does not comply with the corrective action requirements and schedule established under rule 3745-81-61 of the Administrative Code.

(B) Unless the director invalidates an E. coli positive ground water source sample in accordance with paragraph (D) of rule 3745-81-42 of the Administrative Code, a ground water system is in violation of the treatment technique requirement if the system does not comply with the corrective action requirements and schedule established under rule 3745-81-61 of the Administrative Code.

(C) A ground water system subject to paragraph (A)(2) of rule 3745-81-43 of the Administrative Code that fails to maintain at least 4-log treatment of viruses (using inactivation, removal, or a director-approved combination of 4-log virus inactivation and removal) before or at the first customer for a ground water source is in violation of the treatment technique requirement if the failure is not corrected within four hours of determining the system is not maintaining at least 4-log treatment of viruses before or at the first customer.

(D) A ground water system must give public notification in accordance with paragraph (C)(1)(a) of rule 3745-81-32 of the Administrative Code for the treatment technique violations specified in paragraphs (A) to (C) of this rule.
