

Ohio Administrative Code

Rule 4123:1-17-07 Miscellaneous requirements.

Effective: February 1, 2025

(A) Portable extension sills.

(1) Portable extension sills shall be no less than ten inches (25.4 centimeters) wide nor less than

thirty inches (76.2 centimeters) long and shall be substantially constructed. The portable extension

sill shall be securely fastened in place during window cleaning operations.

(2) Portable extension sills shall not be used when window sills extend six inches (15.2 centimeters)

or more beyond the window frame.

(3) Portable extension sills shall be used only when the window cleaner is provided with a safety belt

or a safety harness, with a lifeline, in compliance with rule 4123:1-17-06 of the Administrative

Code, and anchors are available.

(B) Window jacks and other platform devices.

Window jacks and all other platform devices fastened to window sills shall be used only when the

window cleaner is provided with a safety belt or a safety harness, with a lifeline, in compliance with

rule 4123:1-17-06 of the Administrative Code, and anchors are available.

(C) Back supports for extra width windows.

Where the distance between anchors is more than six feet (1.8 meters), a wire rope or corrosive

resistant chain shall be provided on such windows to be used as a back support for the window

cleaner.

(D) Stepping from window to window not permitted.

Window cleaners shall not step from window to window on the outside of the building.



(E) Anchors.

When a safety belt or a safety harness is required in window cleaning, no window cleaner shall work on a window if any anchor is found to be loose, insecure, or missing.

(F) Extension tools.

Each extension tool shall be equipped with a locking device which prevents accidental detachment of the window cleaning tool. The overall length of a tool with extensions shall not exceed six feet (1.8 meters) when used from any working position above the ground or alternatively above an unobstructed setback level having an outer balustrade or wall extending no less than forty-two inches (106.7 centimeters) above the setback level.