



Ohio Administrative Code Rule 5507-1-10 Emergency power.

Effective: [May 12, 2016](#)

(A) The PSAP shall have a minimum one alternate/emergency power supply capable of supporting (maintaining) 9-1-1 call handling/processing equipment and necessary related public safety (communications) services for a minimum of twenty-four hours.

(B) An uninterrupted power supply (UPS) and battery system shall be installed and sufficient enough to prevent power surges and provide continuous power to essential 9-1-1 equipment until the generator or other backup power source can fully activate.
