

1301:7-7-34 Tire rebuilding and tire storage.

Chapter 34 of the International Fire Code, 2021 edition, as incorporated by reference and modified in Section 101.1.1 of this code, is further modified as follows:

1. **Modify section 3401.2 Permit required** as follows:

Delete “Section 105.5” and insert “Chapter I”.

2. **Modify section 3403.1. Construction** as follows:

Delete “International Building Code” and insert “building code”.

3. **Modify section 3405.1 Individual piles** as follows:

In the first sentence

Delete “5,000” and insert “2,500”;

Delete “464.5” and insert “232”;

At the end of the sentence after “continuous area” insert “unless a larger area is specifically authorized in accordance with Chapter 3734. of the Revised Code”.

In the second sentence

Delete “50,000” and insert “20,000”;

Delete “1416” and insert “566”;

Delete “10” and insert “8”;

Delete “3048” and insert “2438”;

At the end of the sentence after “in height” insert “unless a larger area is specifically authorized in accordance with Chapter 3734. of the Revised Code”.

4. **Modify section 3405.2 Separation of piles** as follows:

Delete “40” and insert “56”;

Delete “12 192” and insert “17 069”;

Insert and exception as follows: “**Exception:** If the total number of tires in the pile is 500 or less, the individual storage piles shall be separated from other piles of salvage by a clear space of at least 25 feet (7620 mm).”.

5. **Modify section 3405.3 Distance between piles of other stored products** as follows:

Delete “40” and insert “56”;

Delete “12 192” and insert “17 069”;

Insert an exception as follows: “**Exception:** If the total number of tires in the pile is 500 or less, the tire storage piles shall be separated by a clear space of at least 25 feet (7620 mm) from piles of other stored product.”.

6. **Modify section 3405.4 Distance from lot lines and buildings** as follows:

Delete “50” and insert “56”;

Delete “15 240” and insert “17 069”;

Insert an exception as follows: “**Exception:** If the total number of tires in the pile is 500 or less, the tire storage piles shall be located at least 25 feet (7620 mm) from lot lines and buildings.”.

7. **Modify section 3405.5 Fire breaks** as follows:

Delete “40” and insert “56”;

Delete “12 192” and insert “17 069”;

Delete “and for a distance of 100 feet (30 480 mm) from the stored product to”;

Insert an exception as follows: “**Exception:** If the total number of tires in the pile is 500 or less, a clear space of 25 feet (7620 mm) is sufficient.”.

8. **Modify section 3405.6 Volume more than 150,000 cubic feet** as follows:

After “be in accordance with” insert “*Chapter 3734. of the Revised Code and*”.