

**4101:3-9-01 Vents.**

Chapter 9 of the International Plumbing Code, 2021 edition, as incorporated by reference and modified in Section 101.1.1 of this code, is further modified as follows:

**(A) Modify section 901.3 as follows:**

The last sentence is to read: “Air admittance valves for chemical waste systems are to comply with Section 918 including Section 918.8, are to be constructed of materials *approved* in accordance with Section 702.6, and are to be tested for chemical resistance in accordance with ASTM F1412.”

**(B) Modify section 903.1.1 as follows:**

Add the number “12” for the inches value and “304.8” for the mm value.

**(C) Modify section 903.1.2 as follows:**

Add the phrase “within 10 feet (3048 mm) of the occupiable area” at the end of the sentence.

**(D) Modify section 906.5.1 as follows:**

In the first sentence, add the phrase “the building” before “sewer”.

**(E) Modify section 913.2 as follows:**

The last sentence is to read: “The stack is not to receive the discharge of clinical or flushing rim sinks, water closets or urinals.”

**(F) Modify section 918.8 as follows:**

In the first sentence replace the reference “702.5” with “702.6” and in the second sentence, add the phrase “or where limited by the manufacturer’s installation instructions” after “plenums”.

**(G) Modify section 919.1 as follows:**

Replace the reference “316” with “106.5 of the building code”.

Replaces: 4101:3-9-01

Effective: 3/1/2024

Five Year Review (FYR) Dates: 03/01/2029

CERTIFIED ELECTRONICALLY

---

Certification

08/11/2023

---

Date

Promulgated Under: 119.03

Statutory Authority: 3781.10(A)(1), 4104.43 (A)(1)

Rule Amplifies: 3781.10, 3781.11, 3791.04

Prior Effective Dates: 07/01/1998, 01/01/2002, 08/15/2003, 07/01/2007,  
11/01/2011, 03/15/2012, 01/01/2016, 11/01/2017