



Ohio Revised Code

Section 3743.06 Operation of fireworks plants.

Effective: September 30, 2025

Legislation: House Bill 96

In addition to conforming to the rules of the fire marshal adopted pursuant to section 3743.05 of the Revised Code, licensed manufacturers of fireworks shall operate their fireworks plants in accordance with the following:

(A) Signs indicating that smoking is generally forbidden and trespassing is prohibited on the premises of a fireworks plant shall be posted on the premises in a manner determined by the fire marshal.

(B) Reasonable precautions shall be taken to protect the premises of a fireworks plant from trespass, loss, theft, or destruction. Only persons employed by the manufacturer, authorized governmental personnel, and persons who have obtained permission from a member of the manufacturer's office to be on the premises, are to be allowed to enter and remain on the premises.

(C) Smoking or the carrying of pipes, cigarettes, or cigars, matches, lighters, other flame-producing items, or open flame on, or the carrying of a concealed source of ignition into, the premises of a fireworks plant is prohibited, except that a manufacturer may permit smoking in specified lunchrooms or restrooms in buildings or other structures in which no manufacturing, handling, sales, or storage of fireworks takes place. "NO SMOKING" signs shall be posted on the premises as required by the fire marshal.

(D) Fire and explosion prevention and other reasonable safety measures and precautions shall be implemented by a manufacturer.

(E) Persons shall not be permitted to have in their possession or under their control, while they are on the premises of the fireworks plant, any intoxicating liquor, beer, or controlled substance, and they shall not be permitted to enter or remain on the premises if they are found to be under the influence of any intoxicating liquor, beer, or controlled substance.



(F) A manufacturer shall conform to all building, safety, and zoning statutes, ordinances, rules, or other enactments that apply to the premises of its fireworks plant.

(G) Each fireworks plant shall have at least one class 1 magazine that is approved by the bureau of alcohol, tobacco, and firearms of the United States department of the treasury and that is otherwise in conformity with federal law. This division does not apply to fireworks plants existing on or before August 3, 1931.

(H) Awnings, tents, and canopies shall not be used as facilities for the sale or storage of fireworks, except as expressly permitted by section 3743.48 of the Revised Code. This division does not prohibit the use of an awning or canopy attached to a public access showroom for storing nonflammable shopping convenience items such as shopping carts or baskets or providing a shaded area for patrons waiting to enter the public sales area.

(I) Fireworks may be stored in trailers if the trailers are properly enclosed, secured, and grounded and are separated from any structure to which the public is admitted by a distance that will, in the fire marshal's judgment, allow fire-fighting equipment to have full access to the structures on the licensed premises. Such trailers may be moved into closer proximity to any structure only to accept or discharge cargo for a period not to exceed forty-eight hours. Only two such trailers may be placed in such closer proximity at any one time. At no time may trailers be used for conducting sales of any class of fireworks, nor may members of the public have access to the trailers.

Storage areas for fireworks that are in the same building where fireworks are displayed and sold to the public shall be separated from the areas to which the public has access by an appropriately rated fire wall.

(J) A fire suppression system as defined in section 3781.108 of the Revised Code may be turned off only for repair, drainage of the system to prevent damage by freezing during the period of time, approved by the fire marshal, that the facility is closed to all public access during winter months, or maintenance of the system. If any repair or maintenance is necessary during times when the facility is open for public access and business as approved by the fire marshal, the licensed manufacturer shall notify in advance the appropriate insurance company and fire chief or fire prevention officer regarding the nature of the maintenance or repair and the time when it will be performed.



(K) If any fireworks item is removed from its original package or is manufactured with any fuse other than a safety fuse approved by the consumer product safety commission, then the item shall be covered completely by repackaging or bagging or it shall otherwise be covered so as to prevent ignition prior to sale.

(L) A safety officer shall be present during regular business hours at a building open to the public during the period commencing fourteen days before, and ending two days after, each fourth day of July. The officer shall be highly visible, enforce this chapter and any applicable building codes to the extent the officer is authorized by law, and be one of the following:

(1) A deputy sheriff;

(2) A law enforcement officer of a municipal corporation, township, or township or joint police district;

(3) A private uniformed security guard registered under section 4749.06 of the Revised Code.

(M) All doors of all buildings on the licensed premises shall swing outward.

(N) All wholesale and commercial sales of fireworks shall be packaged, shipped, placarded, and transported in accordance with United States department of transportation regulations applicable to the transportation, and the offering for transportation, of hazardous materials. For purposes of this division, "wholesale and commercial sales" includes all sales for resale and any nonretail sale made in furtherance of a commercial enterprise. For purposes of enforcement of these regulations under section 4923.99 of the Revised Code, any sales transaction exceeding one thousand pounds shall be rebuttably presumed to be a wholesale or commercial sale.